

INSTITUTE OF ENVIRONMENTAL STUDIES AND WETLAND MANAGEMENT
(Department Of Environment, Government of West Bengal)
DD-24, Sector-I, Salt Lake City, Kolkata-700 0064.
Phone Nos. 2334-0239/0531
Fax: 033 2358 0967

Enquiry No.06-IESWM/ENQ/5M-13/2026-27[135B]

Dated.31.07.2026

Sealed quotations addressed to the Director, IESWM, are invited for the items/works, printed overleaf, which will be received up to **2.00PM on 10.08.2026** at the above addressed office. The quotations received will be opened **at 3.00PM on 10.08.2026** before the representative of the organization, who may be present.

Please quote the Enquiry Number and the Date of Opening., as given above, on the sealed envelope. Photocopy of Trade License and GST No. of the organization stated be attached along with the quotation.

Supply/Works shall have to be completed within 7 (seven) days from the date of the receipt of the order unless otherwise stated. Payment shall be made within (30) thirty days after satisfactory Supply / works including installation (if applicable), duly certified by the consignee.

Sd/-
Director, IESWM

Sl. No.	Specification	Quantity Required	Remarks
1.	Item: Supply, Installation, Testing and Commissioning of 5 HP Open Well Submersible Pump Set Technical Specifications: - Type: Open Well Submersible Pump Set - Rated Power: 5 HP (3.7 kW) - Power Supply: 415 Volts $\pm 10\%$, 3 Phase, 50 Hz AC - Motor Type: Water-filled/Rewindable Submersible Motor suitable for continuous duty - Pump Type: Open Well Submersible - Discharge Size: 40 mm (1.5") or compatible with existing pipeline - Head: Suitable for lifting water from Ground Floor Reservoir to 7th floor Rooftop Overhead Tank (approximately 30 metres Total Dynamic Head) - Pump Casing: Cast Iron with anti-corrosive coating - Cable: Minimum 10 metres heavy-duty submersible cable with waterproof jointing kit Scope of Work - Supply, installation, testing and commissioning of the new 5 HP Open Well Submersible Pump Set. - Necessary alignment, coupling, electrical connections, and integration with the existing delivery pipeline. - Trial run for satisfactory performance. - Handing over the pump in fully operational condition. Warranty: Minimum 12 months comprehensive onsite warranty from the date of successful commissioning. Make: ISI-marked make, conforming to the relevant BIS/IS standards.	1 no.	For lifting water from Ground Floor Reservoir to 7 th floor Rooftop Overhead Tank in replace of breakdown pump